

ITEMS CHECKED DURING A SWIMMING POOL INSPECTION

Personnel

1. Licensed Pool Operator on duty
2. Qualified Lifeguard on duty

Records

3. Records adequate and current
4. Reporting Illness, Accidents

Postings

5. Appropriate warnings and prohibitions
6. Emergency phone numbers
7. Rules
8. Licenses and permits

Safety Equipment

9. Ring buoy with adequate rope
10. 12 foot pole
11. Backboard and 2 blankets
12. First aid kit
13. Elevated lifeguard platform or chairs
14. Lifesaving equipment properly located
15. Emergency care area, telephone

Bathhouse

16. Floors: clean, in good repair
17. Walls & ceilings: clean, in good repair
18. Adequate lighting and ventilation
19. Plumbing: no leaks, adequate supply of warm water to showers and hand basins
20. Plumbing: no cross-connections
21. Plumbing fixtures: clean, in good repair
22. Plumbing fixtures: Adequate toilets, urinals, hand basins and showers
23. Dressing and Sanitary Facilities: Furnished suits & towels: properly washed and disinfected
24. Adequate supplies: Soap & soap dispensers, toilet tissue, receptacles (showers & sinks)

Deck & Pool

25. Lighting: approved wiring and fixtures
26. Adequate lighting and fixtures in good repair
27. Diving board: approved, properly secured, adequate, and in good repair
28. Ladders & steps: adequate, properly secured, in good repair, slip-resistant treads
29. Depth markings: plainly marked, appropriately located
30. Drinking fountain: present, clean, good repair

Deck & Pool (con't)

31. Decks & walkways: sufficient width, good repair, clean, properly drained, impervious and with a slip-resistant surface
32. Pool side & bottom: clean, good repair no algae
33. Bathing load: safety standards observed
34. Fencing & gates: properly constructed, in good repair, sufficient height, appropriate latches & locks
35. Spectators: excluded from deck and pool area
36. Food & beverage: excluded from deck and pool area

Premises

37. Drainage: no standing water or muddy areas
38. Refuse storage: appropriate containers used, litter properly containerized
39. Equipment access and security
40. Physical facilities – clean, in good repair

Water Treatment & Equipment

41. Water level: sufficient for maintaining a continuous skimming action
42. Skimmers: weirs present and functioning, basket in place
43. Scum gutter: clean and free flowing
44. Filter room: clean, adequate lighting, drained, vented
45. Piping: no cross connections
46. Piping: hair and lint catchers
47. Piping: grates over deck and pool drains
48. Filters & pumps: good repair, operating, air relief valve, flow meter, pressure gauges
49. Disinfectant & chemical feeders: disinfectant and other chemical feeder in good repair and operating
50. Vacuum cleaning equipment: present, in good repair
51. Chemicals: properly stored, properly used, sufficient quantity on hand
52. Test kits: appropriate and usable pH and disinfectant measuring equipment available
53. Water Quality, Source, & Temperature
54. Other: Pest Control

In addition, the following items will be check:

Pool Volume gallons
Clarity
Deep end free Chlorine residual
Flow Meter Reading (gpm)
Shallow end pH Reading
Combined chlorine residual

Pressure Gauge Readings
both Influent (psi) and Effluent (psi):
Total alkalinity
Cyanuric acid concentration
Shallow end free chlorine residual